



TO SECURE GROUND LUG TO FRAME USE EXTERNAL STAR WASHER BETWEEN LUG AND FRAME AND SECURE WITH #8 SHEET METAL SCREW.  
USE UL LISTED GROUND LUG.

120 VAC  
NOTE:  
PLUG IS NOT SUITABLE AS A DISCONNECT. USER MUST SUPPLY A SUITABLE DISCONNECT.

VOLTAGE - 120VAC  
14 AMPS  
1 HP SINGLE PHASE/50/60 HZ.  
20 AMP BRANCH CIRCUIT PROTECTION TO BE PROVIDED BY OTHERS DURING FIELD INSTALLATION.

NAME:  
WIRING DIAGRAM  
MARK II TICKET DELIVERY SYSTEM (LCD TYPE)  
3 DR 4 INCH

PART NO.  
E-11878WD

CAD FILE: A20

DATE: 09/30/02  
DRAWN BY: JAC  
REVISIONS:  
2-10/23/02 7--08/05/03  
3-12/17/02 8--08/07/03  
4-04/10/03  
5-05/02/03  
6-07/03/03

INFORMATION CONTAINED HEREIN IS PROPRIETARY TO EAGLE PNEUMATIC, INC ALL RIGHTS RESERVED.

TOLERANCES:  
UNLESS OTHERWISE SPECIFIED FRACTIONS +/- 1/32"  
DECIMALS +/- .005"

INFO: PNEUMATIC, INC. (863)644-4870

NOTE:  
GREEN LED ON SIGNIFIES STATIONS READY  
RED LED ON SIGNIFIES STATIONS IN USE

**FUNCTION OF INDICATOR LED'S ON PCB**

- A ● INDICATES REMOTE SEND SWITCH IS OPERATED
- B ● NOT USED
- C ● INDICATES LOCAL SEND SWITCH IS OPERATED
- D ● INDICATES LOCAL DOOR IS CLOSED
- E ● NOT USED
- F ● NOT USED
- G ● NOT USED
- H ● INDICATES LOCAL GREEN LED IS LIT
- I ● INDICATES LOCAL RED LED IS LIT
- J ● INDICATES LOCAL DOOR IS LOCKED
- K ● INDICATES VACUUM MOTOR IS RUNNING
- L ● INDICATES PRESSURE MOTOR IS RUNNING
- M ● INDICATES POWER IS ON
- N ● BLINKING INDICATES PROGRAM IS OPERATIONAL

**CIRCUIT BOARD SHORTING BLOCKS**

- J1 — NONE
- J2 — NONE
- J3 — NONE
- J4 — NONE
- J7 — NONE
- J9 — NONE
- J10 — NONE

